



Office of the District Fire Officer,
Anjanapura Fire Station.



Karnataka Fire & Emergency Services,
Anjanapura, Bengaluru 560 108.

No.10/DFO/AFS/BLR/School/2024

Dated:03-05-2024.

"Annexure-2"

To,
The Authorized Signatory
Sharada Vidya Mandira
Sy.No-237/1, 237/2 & 288/5,
Ayyappa Swamy Temple Road, Kadugodi,
Whitefield Railway Station,
Bengaluru-560 067.

Sir,

Sub : Issue of "Fire Safety Compliance Report" with respect to fire prevention, fire fighting and evacuation measures maintained at **"Sharada Vidya Mandira, Sy.No- 237/1, 237/2 & 288/5, Ayyappa Swamy Temple Road, Kadugodi, Whitefield Railway Station, Bengaluru-560 067"** - reg.

Ref : 1) FSR No.10/DFO/AFS/FSR/2024, Date: 03-05-2024.
2) Your request letter dated: 24-04-2024.

<<<>>>

With reference to the above cited subject, as per ref(1), a conditional Fire Safety Recommendation was issued to the premises of **"Sharada Vidya Mandira, Sy.No-237/1, 237/2 & 288/5, Ayyappa Swamy Temple Road, Kadugodi, Whitefield Railway Station, Bengaluru-560 067"** with a condition to fulfill the recommendations and compliance the same within 3 months.

With reference cited (2) above, the management of **"Sharada Vidya Mandira,"** had requested for the fire safety compliance report from our department. In this regard the above addressed educational building was inspected by me on 24-04-2024 for issue of fire safety compliance report.

Under the above circumstance the Karnataka Fire & Emergency Services Department is issuing the "Fire Safety Compliance Report" to **"Sharada Vidya Mandira, Sy.No-237/1, 237/2 & 288/5, Ayyappa Swamy Temple Road, Kadugodi, Whitefield Railway Station, Bengaluru-560 067"** subject to proper maintenance of fire fighting installations in the good working conditions and arrange for 40% of staffs/ employees training within 03 months from the date of issue of this report. "This Fire Safety Compliance Report is valid for Only One Year from the date of issue and it is renewable".



Yours faithfully

DISTRICT FIRE OFFICER
Anjanapura Fire Station,
BENGALURU - 560 108.



Office of the District Fire Officer,
Anjanapura Fire Station.
Karnataka Fire & Emergency Services,
Anjanapura, Bengaluru 560 108.



No.10/DFO/AFS/BLR/School/2024

Dated:03-05-2024.

ANNEXURE – 1

Group - B Educational Building

NBC-2016, Part-4, Table 7(11) 3.1.3 Group B Educational Buildings Sub Division B1 & B2.

(These condition are indicative and not exclusive all relevant provisions related to fire and life safety of NBC-2016 are mandatory).

To,
The Authorized Signatory
Sharada Vidya Mandira
Sy.No-237/1, 237/2 & 288/5,
Ayyappa Swamy Temple Road, Kadugodi,
Whitefield Railway Station,
Bengaluru-560 067.

Sir,

Sub : Issue of "Fire safety recommendation"with respect of fire prevention, fire fighting and evacuation measures required at "**Sharada Vidya Mandira, Sy.No-237/1, 237/2 & 288/5, Ayyappa Swamy Temple Road, Kadugodi, Whitefield Railway Station,Bengaluru-560 067**"- reg.

Ref : 1) Your request letter dated: 24-04-2024.

<<<>>>

With reference to the subject cited above, the premises of "**Sharada Vidya Mandira, Sy.No-237/1, 237/2 & 288/5, Ayyappa Swamy Temple Road, Kadugodi, Whitefield Railway Station,Bengaluru-560 067**" was inspected by me on 24-04-2024 with respect to Fire prevention, Fire fighting and Evacuation measures to be complied in the above premises and has submitted the details as under.

A. Details of the building / premises :-

01	Name and Address of the Applicant.	: The Authorized Signatory Sharada Vidya Mandira Sy.No-237/1, 237/2 & 288/5, Ayyappa Swamy Temple Road, Kadugodi, Whitefield Railway Station, Bengaluru-560 067.
02	Name and Address of the premises.	: Sharada Vidya Mandira Sy.No-237/1, 237/2 & 288/5, Ayyappa Swamy Temple Road, Kadugodi, Whitefield Railway Station, Bengaluru-560 067.



03	Name and address of the Building owner	:	The Authorized Signatory Sharada Vidya Mandira Sy.No-237/1, 237/2 & 288/5, Ayyappa Swamy Temple Road, Kadugodi, Whitefield Railway Station, Bengaluru-560 067.
04	Number of buildings	:	One Building.
05	Number of floors	:	Ground & 03 Upper floors.
06	Floor-wise details of occupancy: -		
	Ground floor	:	01 staff room, 01 yoga room, 01meeting room, 04 Class Rooms & Wash Rooms.
	1 st floor	:	08 Class Rooms, 01 staff room& Wash Rooms.
	2 nd floor	:	05 Class Rooms, 01 physics lab, 01 chemistry lab, 01 biology lab& Wash Rooms.
	3 rd floor	:	05 Class Rooms, 01 staff room, 01 library, 01 computer lab& Wash Rooms.
07	Height of the Building.	:	12.80 Mtrs.
08	Site area	:	02 acre 20 guntas.
09	Built-up area of each floor: -		
	Ground floor	:	942.00Sq.Mtrs.
	1 st floor	:	942.00Sq.Mtrs.
	2 nd floor	:	942.00Sq.Mtrs.
	3 rd floor	:	942.00Sq.Mtrs.
10.	Total built-up area	:	3768.00Sq.Mtrs.
11	Surrounding properties: -		
	West(Front)	:	Abutting Ayyappa Swamy Temple road.
	East(Rear)	:	Residential building.
	North(Side)	:	Private property.
	South(Side)	:	Private property.



12	Set-back area available around the building: -		
	West(Front)	:	06.00 Mtrs.
	East(Rear)	:	02.00 Mtrs.
	North(Side)	:	06.00 Mtrs.
	South(Side)	:	10.00 Mtrs.

B. On inspection of this School premises, the following fire prevention, fire fighting and evacuation measures recommended are considered absolutely essential from fire safety point of view :-

Sl. No. (1)	Details (02)	Existing (03)	Recommendations (04)	
01.	Accessibility to the premises	The premises is accessible from 08.00 mtrs wide Ayyappa swmay temple road connected to Kadugodi roadlocated on the westernside. The road is hardened to carry the weight of 45.000 kgs.	Complied.	
02.	No. of entrances	One entrancecum exit has been provided.	Complied.	
03.	Width of Entry/Exit	6.00 mtrs.	Complied.	
04.	Diesel generators.	62.5 KVA capacity generatorshave been provided.	Complied.	
05.	No. of staircases available	Nos. of staircases	: 02no.s	Complied.
		Width of staircases	: 1.50 mtrs.	
		Width of threads	: 30 cm	
		Height of risers	: 16 cm	
		Number of risers per flight	: 07 nos.	
		Height of handrails.	: 01.00 mtrs.	
	Head room clearance	: 02.60Mtrs.		



06.	Fire extinguisher	02nos. Co2 type extinguisher of 4.5 kg capacity, 25nos. ABC type extinguisher of 6.0 kg capacity has been provided.	Complied.
07.	Hose reel hoses.	Hose reel hose is of 19 mm size of adequate length to reach the farthest point of both building each floor has been provided with a shut off branch having a nozzle of 5 mm size. The hose reel hose system has been connected to an overhead tank of 10,000 ltrs water capacity.	Complied.
08.	Terrace tank over respective tower terrace.	One Overhead tank of 10,000 ltrs. capacity has been Provided.	Complied.
09.	At the terrace tank level with minimum pressure of 3.5 kg/cm ² .	An electrically driven pump capable of delivering 450 LPM at minimum pressure of 3.5 kg/cm ² has been installed near the overhead tank.	Complied.
10.	Escape routes	Marked at each floor of each to guide the employees in case of any emergency.	Complied.
11.	Fire order	A Notice Board indicating with the details of action to be taken by the employees in case of an emergency/fire has been displayed in prominent places.	Complied.
12.	No smoking board.	Displayed.	Complied.
13.	Fire Siren	A fire siren has been installed inside the premises to inform all the inmates in case of a fire emergency and evacuate the area.	Complied.
14.	Nominate one fire Nodal officer.	One non teaching staff has been nominated as fire nodal officer for the school premises.	Complied.



15.	Fire fighting training	Not provided.	40% of the staffs/Teachers shall be got trained in fire prevention, fire fighting & evacuation at R.A.Mundkur fire & emergency service Academy, Bannerghatta road, Bangalore-560 029.
16.	<p>General Fire precaution measures :-</p> <p>A. Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory & electrical sum panel premises.</p> <p>B. Accumulation of combustibile waste in and around the premises should be avoided.</p> <p>C. The exit ways shall be always kept clear without any obstruction.</p> <p>D. Liquefied petroleum gas should be not stored in the building.</p> <p>E. The doors shall not be kept locked/latched during working hours and shall be free from obstruction.</p> <p>F. During the class hours the class room doors shall not be locked from inside to outside.</p> <p>G. As per Hon'ble Supreme Court order all teacher and staff shall be trained to handle safety equipment, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety day on April 14th of every year by conducting fire safety drills with co-ordinate with Fire Service Department.</p> <p>H. This Fire Safety Recommendation is issued from the fire prevention, fire fighting and evacuation measures. Karnataka State Fire & Emergency Services Department is not responsible for the ownership of the land, its location and other disputes, which may arise in due course.</p>		

Under the above circumstance, the Karnataka Fire & Emergency Services Department is issuing Fire Safety Recommendation to "Sharada Vidya Mandira, Sy.No-237/1, 237/2 & 288/5, Ayyappa Swamy Temple Road, Kadugodi, Whitefield Railway Station, Bengaluru-560 067" subject to condition and compliance of the above recommendations as shown in Column-4 of Part-B within 3 months and compliance from the undersigned.

"This Fire Safety Recommendation is valid for Only One Year from the date of issue and it is renewable."

All requirements recommended above are as per National Building Code-2016 Part-4 clause 3.1.3 of Fire and Life safety will have to be complied with mandatorily.



Yours faithfully

DISTRICT FIRE OFFICER
Anjanapura Fire Station,
BENGALURU - 560 108.

